



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC23024402900

Valid from: Aug.31,2023

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT Slenergy Technology (A.H.) Co., Ltd.
No. 120 Yongyang Road 239000 Chuzhou, Anhui PEOPLE'S REPUBLIC OF CHINA

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Slenergy Technology (A.H.) Co., Ltd.
No. 120 Yongyang Road 239000 Chuzhou, Anhui PEOPLE'S REPUBLIC OF CHINA

NAME AND LOCATION OF THE FACTORY Slenergy Technology (A.H.) Co., Ltd.
No. 120 Yongyang Road 239000 Chuzhou, Anhui PEOPLE'S REPUBLIC OF CHINA

PRODUCT NAME, MODEL AND SPECIFICATION PV Grid inverter
see appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS NB/T32004-2018

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

APPENDIX

Page 1 of 2

CERTIFICATE NO.: CQC23024402900

PAPER:

SL50KRG

直流输入:MPPT 电压范围 200V-1000Vdc,最大直流输入电压 1100Vdc,最大输入电流 32A*4; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 84. 1A, 额定交流输出功率 50kW;

SL30KRG

直流输入:MPPT 电压范围 200V-1000Vdc,最大直流输入电压 1100Vdc,最大输入电流 32A*3; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 48. 3A, 额定交流输出功率 30kW;

SL33KRG

直流输入:MPPT 电压范围 200V-1000Vdc,最大直流输入电压 1100Vdc,最大输入电流 32A*3; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 54. 5A, 额定交流输出功率 33kW;

SL36KRG

直流输入:MPPT 电压范围 200V-1000Vdc,最大直流输入电压 1100Vdc,最大输入电流 32A*3; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 60A, 额定交流输出功率 36kW;

SL40KRG

直流输入:MPPT 电压范围 200V-1000Vdc,最大直流输入电压 1100Vdc,最大输入电流 32A*3; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 66. 7A, 额定交流输出功率 40kW;

NOTE: This appendix is valid when used with the certificate.



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

APPENDIX

Page 2 of 2

CERTIFICATE NO.: CQC23024402900

PAPER:

SL40KRG-S

直流输入:MPPT 电压范围 200V-1000Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 32A*4; 交流输出:3/N/PE~, 230V/400V, 50Hz, Max. 66.7A, 额定交流输出功率 40kW;



NOTE: This appendix is valid when used with the certificate.



CHINA QUALITY CERTIFICATION CENTRE